



1" SPRINKLER METER.

### SPRINKLER METER NOTES

1. SPRINKLER METERS MUST BE HORIZONTAL.
2. SPRINKLER METER MUST NOT BE MORE THAN 36" ABOVE FLOOR.
3. SPRINKLER METER SHALL BE LOCATED NEAR DOMESTIC METER.
4. SPRINKLER METER SHALL BE THE SAME SIZE AS DOMESTIC METER.
5. SPRINKLER METER SHALL BE NOT LESS THAN 18" ABOVE DOMESTIC METER.
6. VALVES SHALL BE LOCATED ON BOTH SIDES OF THE SPRINKLER METER.
7. CONNECTIONS MUST BE BRASS OR COPPER - NO PVC OR STAINLESS STEEL IS PERMITTED.



3/4" SPRINKLER METER.

REV. NO.    DATE	Town of East Longmeadow Department of Public Works
SPRINKLER CONNECTIONS	
SCALE: NTS	